



**CITY OF LODI  
COUNCIL COMMUNICATION**

TM

**AGENDA TITLE:** Approve plans and specifications and authorize advertisement for bid for nine (9) self-supporting steel poles (EUD)

**MEETING DATE:** October 6, 2004

**SUBMITTED BY:** Electric Utility Director

---

**RECOMMENDED ACTION:** That the City Council approve the plans and specifications and authorize advertisement for bid for nine (9) self-supporting steel poles.

**BACKGROUND INFORMATION:** The self-supporting steel poles will be used to construct a portion of the 60kV line that will connect the proposed Westside substation to the existing 60kV circuits. The new 60kV line will be constructed on the north and west sides of the new Lowe's development, and on the west and south sides of the proposed development on the southwest corner of Kettleman Lane and Lower Sacramento Road. The self-supporting steel poles are required due to the lack of available space for anchoring and guying at angle and dead-end pole locations.

**FUNDING:** None

A handwritten signature in black ink, reading "Alan N. Vallow".

Alan N. Vallow  
Electric Utility Director

**PREPARED BY:** Al Smatsky, Senior Electrical Estimator

ANV/AMS/lst

cc: City Attorney  
Purchasing Officer

---

**APPROVED:**

A handwritten signature in black ink, reading "Janet S. Keeter".  
Janet S. Keeter, Interim City Manager